

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E474828  
**Report Reference** E474828-20150430  
**Issue Date** 2020-SEPTEMBER-11

**Issued to:** BIMED TEKNIK ALETLER SAN TIC A S  
BEYLIKDUZU MEVKII  
SS BAKIR VE PIRINC SAN  
ORKIDE CD NO 15  
34524 ISTANBUL TURKEY

**This certificate confirms that  
representative samples of**

CABLE FITTINGS FOR USE IN ZONE CLASSIFIED  
HAZARDOUS LOCATIONS  
See next page for models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**  
**Additional Information:**

See page 3 for standards  
See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E474828  
**Report Reference** E474828-20150430  
**Issue Date** 2020-SEPTEMBER-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models:

USL

Cable Fittings, Series Octans, EBU followed by numerals 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 1, AEx e IIC Gb; Zone 21, AEx tb IIIC Db; Hazardous Locations. For use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.

Cable Fittings, Series Octans, EBU followed by numerals 1 thru 12, 23, 34, 45, 56, 67, 78 80, 82 or 810, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 2, AEx e IIC Gc; Zone 22, AEx tc IIIC Dc; Hazardous Locations. For use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive.


Cable Fittings, Series Vela, EBS followed by numerals 1 thru 4, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 1, AEx e IIC Gb; Zone 21, AEx tb IIIC Db; Hazardous Locations. For use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.

Cable Fittings, Series Vela, EBS followed by numerals 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 2, AEx e IIC; Zone 22, AEx tc IIIC Dc; Hazardous Locations. For use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 3 in. NPT inclusive or M20 to M90 inclusive.

CNL

Cable Fittings, Series Octans, EBU followed by numerals 1 thru 4, 12, 23 or 34, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 1, Ex e IIC Gb; Zone 21, Ex tb IIIC Db Hazardous Locations. For use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.

Cable Fittings, Series Octans, EBU followed by numerals 1 thru 12, 23, 34, 45, 56, 67, 78 80, 82 or 810, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 2, Ex e IIC Gc; Zone 22, Ex tc IIIC Dc Hazardous Locations. For use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 4 in. NPT inclusive or M20 to M110 inclusive.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E474828  
**Report Reference** E474828-20150430  
**Issue Date** 2020-SEPTEMBER-11

Cable Fittings, Series Vela, EBS followed by numerals 1 thru 4, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 1, Ex e IIC Gb; Zone 21, Ex tb IIIC Db Hazardous Locations. For use only with TC-ER-HL cable. Thread sizes 1/2 to 1-1/4 in. NPT inclusive or M20 to M40 inclusive.

Cable Fittings, Series Vela, EBS followed by numerals 1 thru 12, followed by M or N, followed by B, BN, X or A, followed by C or S, may be followed by -WC or -WS for use in Class I, Zone 2, Ex e IIC Gc; Zone 22, Ex tc IIIC Dc Hazardous Locations. For use only with TC, TC-ER and TC-ER-HL cable. Thread sizes 1/2 to 3 in. NPT inclusive or M20 to M90 inclusive.


## Standards:

Standard No. UL 2225, 4th Ed., Rev. 2016-01-29, Cables and Cable-Fittings for Use in Hazardous (Classified) Locations

Standard No. CSA C22.2 No. 60079-0 Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements

Standard No. CSA C22.2 No. 60079-7 Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety "e"

Standard No. CSA C22.2 No. 60079-31 Explosive Atmospheres - Part 31: Equipment Dust Ignition Protection by Enclosure "t"



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

